


DURAMAX BOILER DW (720-1810) - THREE BOILERS / HORIZONTAL STORAGE TANK RECOVERY SYSTEM (ONE TEMPERATURE)

<u>WARNING:</u> THIS DRAWING SHOWS SUGGESTED PIPING CONFIGURATION AND OTHER DEVICES; CHECK WITH LOCAL CODES AND ORDINANCES FOR ADDITIONAL REQUIREMENTS.

LEGEND

TEMPERATURE & PRESSURE RELIEF VALVE	TANK TEMPERATURE CONTROL	\bigvee^{h}	CHECK VALVE
PRESSURE RELIEF VALVE	☐ DRAIN		TEMPERATURE GAGE
CIRCULATING PUMP	FULL PORT BALL VALVE	P	WATER FLOW SWITCH

BOILER MODEL (DW)	BOILER PIPING SIZE "A" (INCH)	MANIFOLD PIPING SIZE "B" (INCH)
720-840	2	3
960-1810	2 1/2	4



NOTES:

- 1. Preferred piping layout.
- 2. The temperature and pressure relief valve setting shall not exceed pressure rating of any component in the system.
- 3. Service valves are shown for servicing boiler. However, local codes shall govern their usage.
- 4. A. O. Smith piping method is based on 50 equivalent feet of piping. Boiler placement shall be as close as practical to the storage tank. Applications in excess of these recommendations shall require a licensed engineer for design assistance.