


AWH - TWO AIR TO WATER HEAT PUMPS, VERTICAL STORAGE TANK WITH FORCED BUILDING RECIRCULATION (ONE TEMPERATURE)

WARNING: THIS DRAWING SHOWS SUGGESTED PIPING CONFIGURATION AND OTHER DEVICES; CHECK WITH LOCAL CODES AND ORDINANCES FOR ADDITIONAL REQUIREMENTS.


ANY MATERIAL, COMPONENT OR VENDOR CHANGE MUST HAVE PRIOR APPROVAL BY THE APPLICABLE PRODUCT ENGINEERING DEPARTMENT.

LEGEND



IMPORTANT INSTALLATION NOTES

MULTIPLE HPWHS MUST BE PIPED IN REVERSE RETURN PIPING CONFIGURATION AS SHOWN IN THIS DIAGRAM.



NOTES:

- 1. Preferred piping method.
- 2. The temperature and pressure relief valve setting shall not exceed pressure rating of any component in the system.
- 3. Service valves are shown for servicing unit. However, local codes shall govern their usage.