


| MODEL NO. | L | W | Ds | Hs | Db | Hb |
|-------------|----|----|----|-----|----|----|
| C43-0075-15 | 37 | 18 | 13 | 69 | 18 | 40 |
| C43-0090-15 | 44 | 24 | 14 | 80 | 24 | 41 |
| C43-0120-15 | 46 | 24 | 16 | 80 | 24 | 41 |
| C43-0150-15 | 48 | 24 | 18 | 82 | 24 | 50 |
| C43-0180-15 | 51 | 24 | 21 | 82 | 24 | 50 |
| C43-0210-15 | 51 | 24 | 21 | 82 | 24 | 50 |
| C43-0240-15 | 54 | 24 | 24 | 89 | 24 | 50 |
| C43-0270-15 | 54 | 24 | 24 | 89 | 24 | 50 |
| C43-0300-15 | 60 | 30 | 24 | 89 | 30 | 50 |
| C43-0450-15 | 66 | 30 | 30 | 101 | 30 | 50 |

NOTES:

- 1) VALVE INLET AND OUTLET CONNECTIONS ARE 1-1/2" NPTF.
- 2) VALVE DRAIN CONNECTION IS 1-1/4" NPTF.
- 3) PIPE AND FITTINGS ARE NOT FURNISHED.
- 4) IT IS RECOMMENDED THAT FLEXIBLE CONNECTORS BE INSTALLED BETWEEN HARD PIPING AND VALVE INLET AND OUTLET CONNECTIONS.
- 5) THE TANK MANUFACTURER RESERVES THE RIGHT TO INVALIDATE THE TANK WARRANTY IF FLEXIBLE CONNECTORS ARE NOT INSTALLED PER NOTE 4.

| | | |
|-------------|-------------------|---|
| SCALE | NTS | LAYOUT DRAWING C43 SERIES - 1-1/2" SINGLE |
| DATE | 02-19-19 | |
| DRAWN | GRBauer |  |
| CHKD | GRB | |
| APPRD. | GRB | |
| DRAWING NO. | C43 1-1/2" SINGLE | |
| REV. | SHEET 1 OF 1 | |